



# **Declaration of Conformity**

| For the following equipment: |  |
|------------------------------|--|
|------------------------------|--|

Model Designation: DRA-x-y (x=40,60; y=12,24); DRC-xy (x=40,60; y=A,B)

is herewith confirmed to comply with the requirements set out in the Council Directive, the following standards were applied:

## RoHS Directive (2011/65/EU), (EU)2015/863

Product Name: Din-Rail Switching Power Supply

Low Voltage Directive (2014/35/EU):

TUV certificate No: R50446402 EN62368-1:2014+A11

### Electromagnetic Compatibility Directive (2014/30/EU):

**EMI (Electro-Magnetic Interference)** 

Conducted emission / Radiated emission

|                  | EN35032.2015+A11.2020    | Class b |
|------------------|--------------------------|---------|
| Harmonic current | EN IEC 61000-3-2:2019    |         |
| Voltage flicker  | EN61000-3-3:2013+A1:2019 |         |

| EMS (Electro-Magnetic Susceptibility) |   |               |                                      |  |
|---------------------------------------|---|---------------|--------------------------------------|--|
| EN55024:2010+A1:2015                  | EN IEC 61204-3:2018 EN55035:2017            | '+A11:2020    |                                      |  |
| ESD air                               | EN61000-4-2:2009                            | Level 3       | 8KV                                  |  |
| ESD contact                           | EN61000-4-2:2009                            | Level 2       | 4KV                                  |  |
| RF field susceptibility               | EN61000-4-3:2006+A1:2008+A2:2010            | Level 2       | 3V/m                                 |  |
| EFT bursts                            | EN61000-4-4:2012                            | Level 2       | 1KV/5KHz                             |  |
| Surge susceptibility                  | EN61000-4-5:2014+A1:2017                    | Level 3       | 1KV/Line-Line                        |  |
| Surge susceptibility                  | EN61000-4-5:2014+A1:2017                    | Level 3       | 2KV/Line-Earth                       |  |
| Conducted susceptibility              | EN61000-4-6:2014                            | Level 2       | 3V                                   |  |
| Magnetic field immunity               | EN61000-4-8:2010                            | Level 2       | 3A/m                                 |  |
| Voltage dip, interruption             | EN IEC 61000-4-11:2020 >95% dip 0.5 periods | 30% dip 25 pe | riods >95% interruptions 250 periods |  |

The power supply is considered as a component that will be operated in combination with final equipment. Since EMC performance will be affected by the complete system, the final equipment manufacturers must re-qualify EMC Directive on the complete system again.

For guidance on how to perform these EMC tests, please refer to TDF (Technical Documentation File).

This Declaration is effective from serial number EC0xxxxxxx

Person responsible for marking this declaration:

MEAN WELL Enterprises Co., Ltd.

(Manufacturer Name)

No.28, Wuquan 3rd Rd., Wugu Dist., New Taipei City 24891, Taiwan

(Manufacturer Address)

(Name / Position)

Johnny Huang/Manager, Certification Center:

Alex Tsai/Director, Marketing Department :

(Name / Position)

(Signature)

Taiwan

Nov. 6th, 2020

(Signature)

(Date)

(Place)