

# CE

Class C( $\geq$ 65% load)

# **Declaration of conformity**

For the following equipment :

Product Name: LED Driver

Model Designation: HBG-60-xy (x=1050, 1400, 2100, y=blank or P)

is herewith confirmed to comply with the requirements set out in the Council Directive, the following standards were applied :

RoHS Directive (2011/65/EU) \ (EU)2015/863

#### Energy-Related Products Directive (2009/125/EC) Implementing measure COMMISSION REGULATION(EC) No 2019/2020

### Low Voltage Directive (2014/35/EU) :

EN 61347-1:2015 EN 61347-2-13:2014/A1:2017

ENEC certificate No:35-102362 (for blank type) ENEC certificate No:35-102363 (for P type)

### Electromagnetic Compatibility Directive (2014/30/EU) :

#### **EMI (Electro-Magnetic Interference)**

Conducted emission / Radiated emission

EN IEC 55015:2019+A11:2020

| Harmonic current | EN IEC 61000-3-2:2019 |
|------------------|-----------------------|
|                  |                       |

Voltage flicker EN 61000-3-3:2013+A1:2019

## EMS (Electro-Magnetic Susceptibility)

| EN 61547:2009             |   |                               |                                  |
|---------------------------|---|-------------------------------|----------------------------------|
| ESD air                   | EN 61000-4-2:2009                       | Level 4                       | 15KV                             |
| ESD contact               | EN 61000-4-2:2009                       | Level 4                       | 8KV                              |
| RF field susceptibility   | EN 61000-4-3:2006+A1:2008+A2            | 2:2010 Level 2                | 3V/m                             |
| EFT bursts                | EN 61000-4-4:2012                       | Level 2                       | 1KV/5KHz                         |
| Surge susceptibility      | EN 61000-4-5:2014+A1:2017               | Level 4                       | 2KV/Line-Line                    |
| Conducted susceptibility  | EN 61000-4-6:2014                       | Level 2                       | 3V                               |
| Magnetic field immunity   | EN 61000-4-8:2010                       | Level 2                       | 3A/m                             |
| Voltage dip, interruption | EN IEC 61000-4-11:2020 7<br>0.5 periods | 70% residual voltage for 10 p | periods, 0% residual voltage for |

#### Note:

Component power supply will be operated with a final equipment. Since EMC performance will be affected by the complete installation, the final equipment manufacturers must re-qualify EMC Directive on the complete installation again. Tests above are only to be performed with LEDs.

For guidance on how to perform these EMC tests, please refer to TDF (Technical Documentation File).

To fulfill requirements of the latest ErP regulation for lighting fixtures, this LED power supply can only be used behind a switch without permanently connected to the mains.

This Declaration is effective from serial number GC1xxxxxx

Person responsible for marking this declaration :

| MEAN WELL Enterprises            | Co., Ltd.                  |  |             |
|----------------------------------|----------------------------|--|-------------|
| (Manufacturer Name)              |                            |  |             |
| No.28, Wuquan 3rd Rd.,           | Wugu Dist., New Taipei Cit | y 24891, Taiwan                                | ~           |
| (Manufacturer Address)           | $\wedge$ -                 |  | QTE         |
| Aries Jian/Director, Group R & D | : Tries                    | Alex Tsai/ Director, Product Strategy Center : |             |
| (Name / Position)                | (Signature)                | (Name / Position)                              | (Signature) |
| Taiwan                           | Aug. 6th, 2021             |  |             |
| (Place)                          | (Date)                     |  |             |