



# **Declaration of Conformity**

For the following equipment.	
Product Name: Switching Power Supply	

Model Designation: HEP-600-x (x=12,15,20,24,30,36,42,48,54) ; HEP-600C-w (w=12,24 or 48)

is herewith confirmed to comply with the requirements set out in the Council Directive, the following standards were applied:

## RoHS Directive (2011/65/EU), (EU)2015/863 Low Voltage Directive (2014/35/EU):

EN62368-1:2014+A11 TUV certificate No: R50448651

### Electromagnetic Compatibility Directive (2014/30/EU):

#### **EMI (Electro-Magnetic Interference)**

Conducted emission / Radiated emission

	EN55032:2015		Class B	
Harmonic current	EN61000-3-2:2014			
Voltage flicker	EN61000-3-3:2013			
EMS (Electro-Magnetic	Susceptibility)			
EN55024:2010+A1:2015				
ESD air	EN61000-4-2:2009	Level 3	8KV	
ESD contact	EN61000-4-2:2009	Level 2	4KV	
RF field susceptibility	EN61000-4-3:2006+A1:2008+A2:2010	Level 3	10V/m	
EFT bursts	EN61000-4-4:2012	Level 3	2KV/5KHz	

Surge susceptibility EN61000-4-5:2014 Level 4 2KV/Line-Line 4KV/Line-Earth Surge susceptibility EN61000-4-5:2014 Level 4 Conducted susceptibility EN61000-4-6:2014 Level 3 10V

Voltage dip, interruption EN61000-4-11:2004 > 95% dip 0.5 periods 30% dip 25 periods > 95% interruptions 250 periods

Level 4

30A/m

A component power supply with load will be installed into final equipment which consists of an electronically shielded metal enclosure. Since EMC performance will be affected by the complete installation, the final equipment manufacturers must re-qualify EMC Directive on the complete installation again.

The EMC tests mentioned above are performed using a well defined metal plate to simulate said metal enclosure.

For guidance on how to perform these EMC tests, please refer to "EMI testing of component power supplies" (as available on http://www.meanwell.com)" and TDF (Technical Documentation File).

This Declaration is effective from serial number RB9xxxxxxx

Person responsible for marking this declaration:

MEAN WELL Enterprises Co., Ltd.

(Manufacturer Name)

Magnetic field immunity

No.28, Wuquan 3rd Rd., Wugu Dist., New Taipei City 24891, Taiwan

EN61000-4-8:2010

(Manufacturer Address)

Alex Tsai/Director, Marketing Department:

Johnny Huang/Manager, Certification Center: (Name / Position) (Signature)

(Name / Position)

(Signature)

Taiwan

Oct. 3rd, 2019

(Place)

(Date)