



A P P R O V A L S ®

Certificate of Approval

Certificate No.: SAA-171152-EA

Certificate Holder: Mean Well Enterprises Co., Ltd.
No. 28, Wuquan 3rd Rd., Wugu Dist.,
New Taipei City 248,
Taiwan

Class Description: Power Supply or Charger
Product Description: LED Controlgear
(Independent SELV, Constant Voltage)

Brand Name: MEAN WELL
Model No.: HLG-600H-.. Series
Markings: Input: 100-240V~ 50/60Hz 7.0A

Output: 12-54Vdc 40-11.2A
ta:50°C tc:90°C, IP67/IP65
Standard: AS/NZS IEC 61347.2.13:2013
AS/NZS 61347.1:2016

Conditions: Nil

Approval Mark: SAA-171152-EA or RCM

Date First Registered: 5 June 2017

Date of Expiry: 5 June 2022


For and on Behalf of
SAA Approvals Pty Ltd

SAA Approvals Pty Ltd as accredited by JAS-ANZ under ISO/IEC 17065 certifies in accordance with the SAA Approvals Electrical Product Safety Certification Scheme that the product nominated in this certificate complies with standard/s listed.

When using the RCM the requirements of all relevant parts of AS/NZS 4417 applicable to the article must be fulfilled.

For SAA Contact Details and to verify this Certificate go to:
www.saaapprovals.com.au

JAS-ANZ



www.jas-anz.org/register



Issued: 05-06-17 171152/1



A P P R O V A L S ®

Certificate of Approval

* Addendum *

Certificate No.: SAA-171152-EA

Date of Issue: 5 June 2017

Class Description: Power Supply or Charger

Product Description: LED Controlgear
(Independent SELV, Constant Voltage)

General Modification:

For HLG-600H... Series:

First '.' denotes output voltage (Vdc) and can be '12', '15', '20', '24', '30', '36', '42', '48' or '54'; and
Second '.' denotes IP rating and dimming function and can be 'A' for IP65 without dimming,
'B' for IP67 with dimming or blank for IP67 without dimming.

A handwritten signature in black ink, appearing to be 'JH', positioned above a horizontal line.


For and on Behalf of
SAA Approvals Pty Ltd

SAA Approvals Pty Ltd as accredited by JAS-ANZ under ISO/IEC 17065 certifies in accordance with the SAA Approvals Electrical Product Safety Certification Scheme that the product nominated in this certificate complies with standard/s listed.

When using the RCM the requirements of all relevant parts of AS/NZS 4417 applicable to the article must be fulfilled.

For SAA Contact Details and to verify this Certificate go to:
www.saaapprovals.com.au

JAS-ANZ



Issued: 05-06-17 171152/2

www.jas-anz.org/register