



UK Declaration of Conformity

For the following equipment :

Product Name: LED Driver

Model Designation: HLX-80H-yz (x=G,N,P ; y=12,15,20,24,30,36,42,48,54 ; z=A or B or D or Blank) ;
HLG-80H-xBL (x=12,15,20,24,30,36,42,48,54)

The designated product(s) is(are) in conformity with the relevant legislation:

The Restriction of the Use of Certain Hazardous Substances in Electrical and Electronic Equipment Regulations 2012: SI 2012 No. 3032

Implementing measure COMMISSION REGULATION(EC) No 2019/2020
The Ecodesign for Energy-Related Products and Energy Information (Amendment) (EU Exit) Regulations 2019

Electrical Equipment (Safety) Regulations 2016 :

BS EN 61347-1:2015

TUV certificate No : R50202561(HLG/HLN-80H)

BS EN 61347-2-13:2014+A1:2017

TUV certificate No : R50201138(HLP-80H)

Electrical Compatibility Regulations 2016 :

EMI (Electro-Magnetic Interference)

Conducted emission / Radiated emission

BS EN 55015:2013+A1:2015

Harmonic current BS EN 61000-3-2:2014 Class C($\geq 60\%$ load)

Voltage flicker BS EN 61000-3-3:2013

EMS (Electro-Magnetic Susceptibility)

BS EN 61547:2009

ESD air	BS EN 61000-4-2:2009	Level 3	8KV
ESD contact	BS EN 61000-4-2:2009	Level 2	4KV
RF field susceptibility	BS EN 61000-4-3:2006+A1:2008+A2:2010	Level 2	3V/m
EFT bursts	BS EN 61000-4-4:2012	Level 2	1KV/5KHz
Surge susceptibility	BS EN 61000-4-5:2014	Level 3	2KV/Line-Line
Surge susceptibility	BS EN 61000-4-5:2014	Level 4	4KV/Line-Earth
Conducted susceptibility	BS EN 61000-4-6:2014	Level 2	3V
Magnetic field immunity	BS EN 61000-4-8:2010	Level 2	3A/m
Voltage dip, interruption	BS EN 61000-4-11:2004	30% dip 10 periods 100% interruptions 0.5 periods	

Note:

Component power supply will be operated with a final equipment. Since EMC performance will be affected by the complete installation, the final equipment manufacturers must re-qualify EMC Regulations on the complete installation again.

Tests above are only to be performed with LEDs.

For guidance on how to perform these EMC tests, please refer to TDF (Technical Documentation File).

To fulfill requirements of the latest ErP regulation for lighting fixtures, this LED power supply can only be used behind a switch without permanently connected to the mains

This Declaration is effective from serial number GC1xxxxxxx

Person responsible for marking this declaration :

MEAN WELL Enterprises Co., Ltd.

(Manufacturer Name)

No.28, Wuquan 3rd Rd., Wugu Dist., New Taipei City 24891, Taiwan

(Manufacturer Address)

Aries Jian/ Director, Group R&D :

(Name / Position)

(Signature)

Alex Tsai/ Director, Product Strategy Center :

(Name / Position)

(Signature)

Taiwan

(Place)

May. 27th, 2021

(Date)