



中国国家强制性产品认证证书

证书编号: 2017011002937819

发证日期: 2022年11月03日

有效期至: 2026年12月23日

认证委托人名称 明纬(广州)电子有限公司
及注册地址 广州市花都区金谷南路11号

产品生产者名称 明纬企业股份有限公司
及注册地址 新北市五股区五权三路28号

生产企业名称 明纬(广州)电子有限公司
及生产地址 广州市花都区金谷南路11号

产品名称和系列、规格、型号 LED 模块用交流电子控制装置(LED 控制装置, 独立式, 恒流模式, 安全特低电压, $t_a: 45^{\circ}\text{C}$, $t_c: 90^{\circ}\text{C}$, II类, IP20, 适宜直接安装在普通可燃材料表面, 不可调光)
见附件。100-240V~ 50/60Hz

产品标准和技术要求 GB 17625.1-2012; GB/T 17743-2021; GB 19510.1-2009; GB 19510.14-2009

上述产品符合 CNCA-C10-01:2014 认证规则的要求, 特发此证。
证书有效期内本证书的有效性依据发证机构的定期监督获得保持。
本证书为变更证书, 证书首次颁发日期: 2017年01月23日
经中国合格评定国家认可委员会认可 CNAS C001-P

可通过扫描下方二维码或登录国家认监委网站 (www.cnca.gov.cn) 查验证书信息



签发:

谢肇煦



中国质量认证中心





CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

CERTIFICATE NO.: 2017011002937819

Valid from: Nov.03,2022

Valid until: Dec.23,2026

**NAME AND REGISTERED
ADDRESS OF THE APPLICANT**

MEAN WELL (Guangzhou) Electronics Co., Ltd.
No.11 Jingu South Road, Huadu District, Guangzhou, China

**NAME AND REGISTERED
ADDRESS OF THE
MANUFACTURER**

MEAN WELL Enterprises Co.,Ltd.
No. 28, Wuquan 3rd Road, Wugu District, New Taipei City, Taiwan

**NAME AND LOCATION
OF THE FACTORY**

MEAN WELL (Guangzhou) Electronics Co., Ltd.
No.11 Jingu South Road,Huadu District, Guangzhou, China

PRODUCT MODEL(S)

A.C.Supplied Electronic Controlgears For LED Modules (Independent ,Constant Current Mode, SELV,
ta:45°C, tc:90°C, Class II, IP20, Suitable For Direct Mounting On Normally Flammable Material,
Non-dimmable)
See Appendix. 100-240V ~ 50/60Hz

**STANDARDS AND
TECHNICAL REQUIREMENTS**

GB 17625.1-2012;GB/T 17743-2021;GB 19510.1-2009;GB 19510.14-2009

This is to certify that the above mentioned product(s) complies with the requirements of implementation rules for compulsory certification(REFNO. CNCA-C10-01:2014)

The validity of the certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

Date of original issued: Jan.23,2017

Accredited by China National Accreditation Service for Conformity Assessment CNAS C001-P

The certificate information is available through the QR code below or CNCA's website: www.cnca.gov.cn



SIGNATURE:

谢肇煦



CHINA QUALITY CERTIFICATION CENTRE





中国国家强制性产品认证证书

证书编号 2017011002937819

第 1 页 共 1 页

本证书及附件应同时使用，信息查验说明见证书页

纸号: 3107976

型号	恒流模式			输出额定功率 (W)
	最大输出电压	额定输出电压	输出电流	
IDLC-25-350	Max.100VDC	49-70VDC	0.35A	24.5
IDLC-25A-350	Max.100VDC	49-70VDC	0.35A	24.5
IDLC-25-500	Max.75VDC	35-50VDC	0.5A	25
IDLC-25A-500	Max.75VDC	35-50VDC	0.5A	25
IDLC-25-700	Max.63VDC	25.2-36VDC	0.7A	25.2
IDLC-25A-700	Max.63VDC	25.2-36VDC	0.7A	25.2
IDLC-25-1050	Max.36VDC	16.8-24VDC	1.05A	25.2
IDLC-25A-1050	Max.36VDC	16.8-24VDC	1.05A	25.2
输入: 100-240V ~ 50/60Hz				
注: 1、以上型号中, 带 "A" 型号为多一组辅助输出, 输出参数为 12VDC, 50mA				
2、以上型号输入额定功率均为 32W。				



中国质量认证中心

