

DK-119166-UL

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Name and address of the applicant

Name and address of the manufacturer

Name and address of the factory

Note: When more than one factory, please report on page 2

Ratings and principal characteristics

Trademark (if any)

Customer's Testing Facility (CTF) Stage used

Model / Type Ref.

Additional information (if necessary may also be reported on page 2)

A sample of the product was tested and found to be in conformity with

As shown in the Test Report Ref. No. which forms part of this Certificate

High Reliable Intelligent Battery Charger

MEAN WELL ENTERPRISES CO LTD NO 28 WUQUAN 3RD RD WUGU DISTRICT NEW TAIPEI CITY 24891 **TAIWAN**

MEAN WELL ENTERPRISES CO LTD NO 28 WUQUAN 3RD RD WUGU DISTRICT NEW TAIPEI CITY 24891 **TAIWAN**

MEAN WELL ENTERPRISES CO LTD NO 28 WUQUAN 3RD RD WUGU DISTRICT NEW TAIPEI CITY 24891 TAIWAN

□ Additional Information on page 2

Input: 100-240Vac, 9A, 50/60Hz □ Additional Information on page 2



CTF Stage 2

NPB-750-x, NPP-750-x □ Additional Information on page 2

Additionally evaluated to:

EN 62368-1:2014/A11:2017, EN 62368-1:2014 National Differences specified in the CB Test Report. ☐ Additional Information on page 2

IEC 62368-1:2014

E183223-A6056-CB-1 issued on 2021-09-30

This CB Test Certificate is issued by the National Certification Body



Date: 2021-10-01

☐ UL (US), 333 Pfingsten Rd IL 60062, Northbrook, USA

☑ UL (Demko), Borupvang 5A DK-2750 Ballerup, DENMARK
☐ UL (JP), Marunouchi Trust Tower Main Building 6F, 1-8-3 Marunouchi, Chiyoda-ku, Tokyo 100-0005, JAPAN
☐ UL (CA), 7 Underwriters Road, Toronto, M1R 3B4 Ontario, CANADA

For full legal entity names see www.ul.com/ncbnames

Signature:

Jan-Erik Storgaard



DK-119166-UL

Factories:

SUZHOU MEAN WELL TECHNOLOGY CO LTD NO. 77, JIAN-MIN ROAD DONG-QIAO PAN-YANG IND. PARK

HUANG-DAI TOWN XIANG-CHENG DISTRICT SUZHOU, JIANGSU, 215152 **CHINA**

MEAN WELL (GUANGZHOU) ELECTRONICS CO LTD HUADU BRANCH NO 11 JINGU SOUTH ROAD **HUADONG TOWN** HUADU DISTRICT GUANGZHOU, GUANGDONG, 510890

CHINA

YONGDEN TECHNOLOGY CORP 345 MACARTHUR HWY TABANG GUIGUINTO, BULACAN, 3015 **PHILIPPINES**

Additional Model Detail(s):

NPB-750-x, NPP-750-x, (where "x" can be 12, 24, or 48)

Additional Ratings:

Input: 100-240Vac, 9A, 50/60Hz

Output:

NPB-750-12, NPP-750-12: 14.4Vdc(10.5Vdc-21Vdc), 43A max,

722.4W max.

NPB-750-24, NPP-750-24: 28.8Vdc(21Vdc-42Vdc), 22.5A max,

756W max.

NPB-750-48, NPP-750-48: 57.6Vdc(42Vdc-80Vdc), 11.3A max,

759.4W max.

Additional information (if necessary)



□ UL (US), 333 Pfingsten Rd IL 60062, Northbrook, USA

■ UL (Demko), Borupvang 5A DK-2750 Ballerup, DENMARK □ UL (JP), Marunouchi Trust Tower Main Building 6F, 1-8-3 Marunouchi, Chiyoda-ku, Tokyo 100-0005, JAPAN □ UL (CA), 7 Underwriters Road, Toronto, M1R 3B4 Ontario, CANADA

For full legal entity names see www.ul.com/ncbnames

Date: 2021-10-01

Signature: Jan-Erik Storgaard