



中国国家强制性产品认证证书

证书编号：2026010907840843

认证委托人名称及地址

苏州明纬科技有限公司
苏州市相城区黄埭镇长平路 269 号

生产者名称及地址

明纬企业股份有限公司
台湾新北市五股区五权三路 28 号

生产企业名称及地址

苏州明纬科技有限公司
苏州市相城区黄埭镇长平路 269 号

产品名称和系列、型号、规格

开关电源

见附页（仅适用于海拔 5000 米及以下）

产品标准和技术要求

GB 17625.1-2022; GB 4943.1-2022; GB/T 9254.1-2021

上述产品符合《强制性产品认证实施规则 电子产品及安全附件》
(CNCA-C09-01:2023) 的要求，特发此证。

发证日期：2026 年 01 月 14 日 有效期至：2031 年 01 月 13 日

证书信息和有效性可扫描下方二维码或登录发证机构网站查验，
也可在认监委网站（www.cnca.gov.cn）查询。

经中国合格评定国家认可委员会认可 CNAS C001-P



签发：

谢肇煦



中国质量认证中心
CHINA QUALITY CERTIFICATION CENTRE

中国质量认证中心有限公司





中国国家强制性产品认证证书

证书编号：2026010907840843

证书附页：第 1 页 共 1 页

NSP-500-xzzzz (x=5,12,15,24,27,36,48,60,x 表示输出电压,影响安全和 EMC 性能;
z 可以是空白、-、0-9、a-z 或 A-Z,仅用于市场目的,不影响安全和 EMC 性能)

申请型号	输入参数	输出电压	输出电流
NSP-500-5zzzz	100-240Vac,5.5-2.3A	5Vdc	90A
NSP-500-12zzzz	100-240Vac, ,6.5-2.6A	12 Vdc	42A
NSP-500-15zzzz		15 Vdc	33.4A
NSP-500-24zzzz		24 Vdc	21A
NSP-500-27zzzz		27 Vdc	18.6A
NSP-500-36zzzz		36 Vdc	13.9A
NSP-500-48zzzz		48 Vdc	10.5A
NSP-500-60zzzz		60 Vdc	8.4A

本页为证书附页，应与证书主页同时使用。



中国质量认证中心
CHINA QUALITY CERTIFICATION CENTRE

中国质量认证中心有限公司



CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

本翻译文件不具有法律效力，
不得单独使用
This translated document
does not have legal validity and
cannot be used in isolation

CERTIFICATE NO.: 2026010907840843

NAME AND ADDRESS OF THE APPLICANT
SUZHOU MEAN WELL TECHNOLOGY CO., LTD.

No.269, Changping Road, Huangdai Town, Xiangcheng District, Suzhou, Jiangsu Province, China.

NAME AND ADDRESS OF THE MANUFACTURER

MEAN WELL Enterprises Co.,Ltd.

No. 28, Wuquan 3rd Road, Wugu District, New Taipei City, Taiwan ,China

NAME AND LOCATION OF THE FACTORY

SUZHOU MEAN WELL TECHNOLOGY CO., LTD.

No.269, Changping Road, Huangdai Town, Xiangcheng District, Suzhou, Jiangsu Province, China.

PRODUCT NAME,MODEL AND SPECIFICATION

SWITCHING POWER SUPPLY

See Appendix (Altitude up to 5000m)

STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB 17625.1-2022;GB 4943.1-2022;GB/T 9254.1-2021

This is to certify that the above mentioned product(s) complies with the requirements of
implementation rules for compulsory certification(REFNO. CNCA-C09-01:2023).

Valid from: Jan.14,2026

Valid until: Jan.13,2031

The certificate information and validity could be checked by scanning the QR code below or logging in to
the website of the issuing authority, or on the website of the CNCA (www.cnca.gov.cn).

Accredited by China National Accreditation Service for Conformity Assessment CNAS C001-P



SIGNATURE:

谢肇煦



中国质量认证中心
CHINA QUALITY CERTIFICATION CENTRE

CHINA QUALITY CERTIFICATION CENTRE CO., LTD.





CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

CERTIFICATE NO. : 2026010907840843

Appendix: Page 1 of 1

NSP-500-xzzzz (x=5,12,15,24,27,36,48,60, x is the output voltage that affects security and EMC performance; z can be blank,-, 0-9, a-z or A-Z and is used only for market purposes without affecting security and EMC performance)

Model	Input	Output voltage	Output current
NSP-500-5zzzz	100-240Vac,5.5-2.3A; 277Vac,2A	5Vdc	90A
NSP-500-12zzzz		12 Vdc	42A
NSP-500-15zzzz		15 Vdc	33.4A
NSP-500-24zzzz		24 Vdc	21A
NSP-500-27zzzz		27 Vdc	18.6A
NSP-500-36zzzz		36 Vdc	13.9A
NSP-500-48zzzz		48 Vdc	10.5A
NSP-500-60zzzz		60 Vdc	8.4A

This page is attached to the certificate and should be used at the same time as the certificate page.



中国质量认证中心
CHINA QUALITY CERTIFICATION CENTRE

CHINA QUALITY CERTIFICATION CENTRE CO., LTD.

本翻译文件不具有法律效力，
不得单独使用
This translated document
does not have legal validity and
cannot be used in isolation