



Declaration of Conformity

Product Name: LED driver

Model Designation:PLN-30-x (x=9, 12, 15, 20, 24, 27, 36, 48)

is herewith confirmed to comply with the requirements set out in the Council Directive, the following standards were applied:

RoHS Directive (2011/65/EU), (EU)2015/863

Energy-Related Products Directive (2009/125/EC) Implementing measure COMMISSION REGULATION(EC) No 2019/2020

Low Voltage Directive (2014/35/EU):

EN 61347-1:2015 ; EN 61347-2-13:2014/A1:2017 TUV certificate No : R50164054

Electromagnetic Compatibility Directive (2014/30/EU):

EMI (Electro-Magnetic Interference)

Conducted emission / Radiated emission

EN IEC 55015:2019+A11:2020

| Harmonic current | EN IEC 61000-3-2:2019 | class C (Pin≧25W) |
|------------------|---------------------------|-------------------|
| Voltage flicker | EN 61000-3-3:2013+A1:2019 | |

EMS (Electro-Magnetic Susceptibility)

| | | | | _ | _ | _ | _ | |
|----|------|----|----|----|---|---|---|---|
| ⊢r | VI 6 | ∹1 | 54 | 7. | 2 | n | n | C |
| | | | | | | | | |

| EN 61547:2009 | | | |
|--------------------------|--|----------------------------|-----------------------------|
| ESD air | EN 61000-4-2:2009 | Level 4 | 15KV |
| ESD contact | EN 61000-4-2:2009 | Level 4 | 8KV |
| RF field susceptibility | EN IEC 61000-4-3:2020 | Level 2 | 3V/m |
| EFT bursts | EN 61000-4-4:2012 | Level 2 | 1KV/5KHz |
| Surge susceptibility | EN 61000-4-5:2014+A1:2017 | Level 3 | 1KV/Line-Line |
| Surge susceptibility | EN 61000-4-5:2014+A1:2017 | Level 3 | 2 KV/Line-earth |
| Conducted susceptibility | EN 61000-4-6:2014 | Level 2 | 3V |
| Magnetic field immunity | EN 61000-4-8:2010 | Level 2 | 3A/m |
| Voltage dip_interruption | EN IEC 61000-4-11:2020 <5% residual voltage for 250 cycles | l voltage for 0.5 cycles , | 70% residual voltage for 25 |

Component power supply will be operated with a final equipment. Since EMC performance will be affected by the complete installation, the final equipment manufacturers must re-qualify EMC Directive on the complete installation again. Tests above are only to be performed with LEDs.

For guidance on how to perform these EMC tests, please refer to TDF (Technical Documentation File).

To fulfill requirements of the latest ErP regulation for lighting fixtures, this LED power supply can only be used behind a switch without permanently connected to the mains.

PLN-30-9 is used for any light source that exempt from the ErP-Directive (EU) 2019/2020 requirement, for example this model could be use for signalling products. (including, but not limited to road-, railway-, marineorair traffic-signalling , traffic control or airfield lamps)

This Declaration is effective from serial number GC1xxxxxxx

Person responsible for marking this declaration:

MEAN WELL Enterprises Co., Ltd.

(Manufacturer Name)

No.28, Wuquan 3rd Rd., Wugu Dist., New Taipei City 24891, Taiwan

(Manufacturer Address)

Aries Jian/Director, Group R & D:

(Name / Position)

Alex Tsai/ Director, Product Strategy Center:

(Name / Position)

(Signature)

Taiwan (Place)

Aug. 16th, 2021 (Date)