



中国国家强制性产品认证证书

证书编号：2015011002773313

委托人名称、地址

明纬（广州）电子有限公司
广州市天河区东圃镇黄村粤安工业园A栋2楼

生产者（制造商）名称、地址

明纬企业股份有限公司
新北市五股区五权三路28号

生产企业名称、地址

明纬（广州）电子有限公司花都分公司
广州市花都区花东镇金谷南路11号

产品名称和系列、规格、型号

LED 模块用交流电子控制装置（LED 控制装置，独立式，恒流模式，安全特低电压， $t_a:40^{\circ}\text{C}$ ， $t_c:75^{\circ}\text{C}$ ，I 类，IP20，适宜直接安装在普通可燃材料表面，定温热保护： 110°C ）

见附件. 100-240V~ 50/60Hz

产品标准和技术要求

GB17625.1-2012; GB/T17743-2017; GB19510.1-2009; GB19510.14-2009

上述产品符合强制性产品认证实施规则 CNCA-C10-01:2014 的要求，特发此证。

发证日期：2020 年 04 月 09 日 有效期至：2025 年 04 月 09 日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

本证书为变更证书，证书首次颁发日期：2015 年 05 月 15 日

本证书的相关信息可通过国家认监委网站 www.cnca.gov.cn 查询
经中国合格评定国家认可委员会认可 CNAS C001-PP



主任：

陆楠



中国质量认证中心



CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

CERTIFICATE NO.: 2015011002773313

NAME AND ADDRESS OF THE APPLICANT

MEAN WELL (Guangzhou) Electronics Co., Ltd.
2/F, A Building, Yuean Ind. Park, Huangcun, Dongpu Town, Tianhe District, Guangzhou, China

NAME AND ADDRESS OF THE MANUFACTURER

MEAN WELL Enterprises Co.,Ltd.
No. 28, Wuquan 3rd Road, Wugu District, New Taipei City, Taiwan

NAME AND ADDRESS OF THE FACTORY

MEAN WELL (Guangzhou) Electronics Co., Ltd Huadu Branch
No.11 Jingu South Road, Huadong Town, Huadu District, Guangzhou, China

PRODUCT NAME, MODEL AND SPECIFICATION

A.C. Supplied Electronic Controlgear For LED Modules (Independent, Constant Current Mode, SELV, ta:40°C, tc:75°C, Class I, IP20, Suitable For Direct Mounting On Normally Flammable Material, Temperature Declared Thermally Protected: 110°C)

See Appendix. 100-240V~ 50/60Hz

THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB17625.1-2012;GB/T17743-2017;GB19510.1-2009;GB19510.14-2009

This is to certify that the above mentioned product(s) complies with the requirements of implementation rules for compulsory certification(REFNO.CNCA-C10-01:2014).

Valid from: Apr.09,2020

Valid until: Apr.09,2025

The validity of the certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

Date of original issued: May.15,2015

The certificate information is available through CNCA's website: www.cnca.gov.cn
Accredited by China National Accreditation Service for Conformity Assessment CNAS C001-P



President:

Lu Mei



CHINA QUALITY CERTIFICATION CENTRE



中国国家强制性产品认证证书

附 录

第 1 页 共 2 页

证书编号：2015011002773313

纸 号：2577357

序号	产品型号	参数	备注
1	PLN-60-12	输出：12V d. c. , 5A (恒流) 配套光源：Max. 60W LED 模块	—
2	PLN-60-15	输出：15V d. c. , 4A (恒流) 配套光源：Max. 60W LED 模块	—
3	PLN-60-20	输出：20V d. c. , 3A (恒流) 配套光源：Max. 60W LED 模块	—
4	PLN-60-24	输出：24V d. c. , 2. 5A (恒流) 配套光源：Max. 60W LED 模块	—
5	PLN-60-27	输出：27V d. c. , 2. 3A (恒流) 配套光源：Max. 60W LED 模块	—
6	PLN-60-36	输出：36V d. c. , 1. 7A (恒流) 配套光源：Max. 60W LED 模块	—
7	PLN-60-48	输出：48V d. c. , 1. 3A (恒流) 配套光源：Max. 60W LED 模块	—
8	PLN-45-12	输出：12V d. c. , 3. 8A (恒流) 配套光源：Max. 45W LED 模块	—
9	PLN-45-15	输出：15V d. c. , 3A (恒流) 配套光源：Max. 45W LED 模块	—
10	PLN-45-20	输出：20V d. c. , 2. 3A (恒流) 配套光源：Max. 45W LED 模块	—
11	PLN-45-24	输出：24V d. c. , 1. 9A (恒流) 配套光源：Max. 45W LED 模块	—
12	PLN-45-27	输出：27V d. c. , 1. 7A (恒流) 配套光源：Max. 45W LED 模块	—

注：此附录与证书同时使用时有效。



主 任：陆 楠



中国质量认证中心



中国国家强制性产品认证证书

附 录

第 2 页 共 2 页

证书编号：2015011002773313

纸 号：2577357

13	PLN-45-36	输出：36V d. c. , 1. 25A (恒流) 配套光源：Max. 45W LED 模块	—
14	PLN-45-48	输出：48V d. c. , 0. 95A (恒流) 配套光源：Max. 45W LED 模块	—
输入：100-240V~, 50/60Hz			

注：此附录与证书同时使用时有效。



主 任：

陆 楠



中国质量认证中心



中国国家强制性产品认证证书

证书编号：2015011002796909

委托人名称、地址

明纬（广州）电子有限公司
广州市天河区东圃镇黄村粤安工业园A栋2楼

生产者（制造商）名称、地址

明纬企业股份有限公司
新北市五股区五权三路28号

生产企业名称、地址

明纬（广州）电子有限公司花都分公司
广州市花都区花东镇金谷南路11号

产品名称和系列、规格、型号

LED 模块用交流电子控制装置（LED 控制装置，部分型号控制端口调光，独立式，恒压模式，安全特低电压， $t_a:50^{\circ}\text{C}$ ， $t_c:85^{\circ}\text{C}$ ，II类，适宜直接安装在普通可燃材料表面，IP20，定温热保护： 110°C ）
见附件。100-240V~ 50/60Hz

产品标准和技术要求

GB17625.1-2012; GB/T17743-2017; GB19510.1-2009; GB19510.14-2009

上述产品符合强制性产品认证实施规则 CNCA-C10-01:2014 的要求，特发此证。

发证日期：2020年01月06日 有效期至：2025年01月06日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

本证书为变更证书，证书首次颁发日期：2015年08月18日

本证书的相关信息可通过国家认监委网站 www.cnca.gov.cn 查询
经中国合格评定国家认可委员会认可 CNAS C0017P



主任：_____

陆梅



中国质量认证中心



CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

CERTIFICATE NO.: 2015011002796909

NAME AND ADDRESS OF THE APPLICANT

MEAN WELL (Guangzhou) Electronics Co., Ltd.
2/F, A Building, Yuean Ind. Park, Huangcun, Dongpu Town, Tianhe District, Guangzhou, China

NAME AND ADDRESS OF THE MANUFACTURER

MEAN WELL Enterprises Co.,Ltd.
No. 28, Wuquan 3rd Road, Wugu District, New Taipei City, Taiwan

NAME AND ADDRESS OF THE FACTORY

MEAN WELL (Guangzhou) Electronics Co., Ltd Huadu Branch
No.11 Jingu South Road, Huadong Town, Huadu District, Guangzhou, China

PRODUCT NAME, MODEL AND SPECIFICATION

A.C. Supplied Electronic Controlgear For LED Modules (Controlled Port Dimming for some type, Independent, Constant voltage Mode, SELV, ta:50°C, tc:85°C, Class II, Suitable For Direct Mounting On Normally Flammable Material, IP20, Temperature Declared Thermally Protected: 110°C)

See Appendix. 100-240V~ 50/60Hz

THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB17625.1-2012;GB/T17743-2017;GB19510.1-2009;GB19510.14-2009

This is to certify that the above mentioned product(s) complies with the requirements of implementation rules for compulsory certification(REFNO.CNCA-C10-01:2014).

Valid from: Jan.06,2020

Valid until: Jan.06,2025

The validity of the certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

Date of original issued: Aug.18,2015

The certificate information is available through CNCA's website: www.cnca.gov.cn
Accredited by China National Accreditation Service for Conformity Assessment CNAS C001-P



President:

Lu Mei



CHINA QUALITY CERTIFICATION CENTRE

<http://www.cqc.com.cn>

Section 9, No. 188, Nanshuan Xilu, Beijing 100070 P. R. China

Tel: +86 10 83886666

Q 2539106



中国国家强制性产品认证证书

变更结论 Modification Approval

证书编号 Certificate No. : 2015011002796909

申请编号 Application No. : A2019CCC1002-3326682

申请人(委托人) Applicant: 明纬(广州)电子有限公司 / MEAN WELL (Guangzhou) Electronics Co., Ltd.

证书编号 Certificate No.(变更前 Original): 2015011002796909

变更产品名称: LED 模块用交流电子控制装置(LED 控制装置, 部分型号控制端口调光, 独立式, 恒压模式, 安全特低电压, ta:50℃, tc:85℃, II类, 适宜直接安装在普通可燃材料表面, IP20, 定温热保护:110℃)

Name of Product Modified: A.C. Supplied Electronic Controlgear For LED Modules (Controlled Port Dimming for some type, Independent, Constant voltage Mode, SELV, ta:50℃, tc:85℃, Class II, Suitable For Direct Mounting On Normally Flammable Material, IP20, Temperature Declared Thermally Protected: 110℃)

变更情况 Situation of Modification (见下表 See table below) :

序号	项目 Item	变更前 Original	变更后 Present
1	产品认证所依据的国家标准、技术规则或者认证实施细则发生了变化	GB/T17743-2007	GB/T17743-2017
2	关键件变更	见检测报告编号: 00501-CG2017-7144	见检测报告编号: 00501-CG2019-13584
3	到期换证	2020-08-18	五年
4	在证书上增加同种产品其它型号	见检测报告编号: 00501-CG2017-7144	见检测报告编号: 00501-CG2019-13584
5	调光方式的变更	见检测报告编号: 00501-CG2017-7144	见检测报告编号: 00501-CG2019-13584

现批准以上变更。

第 1 页 / 共 2 页



主任:

陆梅



中国质量认证中心



中国国家强制性产品认证证书

变更结论 Modification Approval

证书编号 Certificate No. : 2015011002796909

Above Modification is approved. The present will replace the original.

批准日期 (Date) : 2020 年 01 月 06 日

第 2 页 / 共 2 页



主任： 陆楠



中国质量认证中心



中国国家强制性产品认证证书

附 录

第 1 页 共 1 页

证书编号: 2015011002796909

纸 号: 2539106

序号	产品型号	参数	备注
1	PWM-60-24	输出: 24Vd. c., 2.5A (恒压) 配套光源: Max. 60W LED 模块	外接电阻调光
2	PWM-60-24KN		KNX 调光
3	PWM-60-24DA		DALI 调光
4	PWM-60-36	输出: 36Vd. c., 1.67A (恒压) 配套光源: Max. 60.12W LED 模块	外接电阻调光
5	PWM-60-48	输出: 48Vd. c., 1.25A (恒压) 配套光源: Max. 60W LED 模块	外接电阻调光
6	PWM-40-12	输出: 12Vd. c., 3.34A (恒压) 配套光源: Max. 40.08W LED 模块	外接电阻调光
7	PWM-40-24	输出: 24Vd. c., 1.67A (恒压) 配套光源: Max. 40.08W LED 模块	外接电阻调光
8	PWM-40-36	输出: 36Vd. c., 1.12A (恒压) 配套光源: Max. 40.32W LED 模块	外接电阻调光
9	PWM-40-48	输出: 48Vd. c. 0.84A (恒压) 配套光源: Max. 40.32W LED 模块	外接电阻调光
10	PWM-60-12	输出: 12Vd. c. 5A (恒压) 配套光源: Max. 60W LED 模块	外接电阻调光
11	PWM-60-12KN		KNX 调光
12	PWM-60-12DA		DALI 调光

输入: 100-240V~ 50/60Hz

注: 此附录与证书同时使用时有效。



主任: 陆梅



中国质量认证中心