CERTIFICATE

Issued to: Applicant:

MEAN WELL Enterprises Co., Ltd. No.28, Wuquan 3rd Rd, Wugu District 24891 New Taipei City, Taiwan Licensee:

MEAN WELL Enterprises Co., Ltd. No.28, Wuquan 3rd Rd, Wugu District 24891 New Taipei City, Taiwan

Product : Independent LED driver

Trade name(s) : MEAN WELL

Type(s)/model(s) : SLD-150-12, SLD-150-24 and SLD-150-56

The product and any acceptable variation thereto is specified in the Annex to this certificate and the documents therein referred to.

DEKRA hereby declares that the above-mentioned product has been certified on the basis of

- a type test according to the standard(s) EN 61347-1:2015, EN 61347-1:2015/A1:2021
 EN 61347-2-13:2014, EN 61347-2-13:2014/A1:2017 and EN IEC 62384:2020
- an inspection of the factory location according to CENELEC Operational Document CIG 021
- a DEKRA certification agreement with the number 2175773

DEKRA hereby grants the right to use the ENEC certification mark

The ENEC certification mark may be applied to the product as specified in this certificate for the duration and under the conditions of the ENEC certification agreement.

This certificate is issued on 27 February 2023 and expires upon withdrawal of one of the above mentioned standards.

Certificate number: 35-127559

DEKRA Certification B.V.

B.T.M. Holtus Managing Director KX

Certification Manager

© Integral publication of this certificate is allowed

ACCREDITED BY THE DUTCH ACCREDITATION COUNCIL







SPECIFICATION OF THE CERTIFIED PRODUCT

Product data

Product : Independent LED driver

Trade name(s) : MEAN WELL

Type(s)/model(s) : SLD-150-12, SLD-150-24 and SLD-150-56

Rated input voltage : 120-277 V~ Rated input current : 2,0 A Rated frequency : 50/60 Hz Max. case temperature (tc) : 85 °C Ambient temperature (ta) : 40 °C Power factor : 0,95 Class of insulation : Class II Degree of protection : IP20

Additional information : SELV, Thermal, short-circuit and overload protection

Product data – type SLD-150-12

Output Rated : Max. 13 Vdc

12 Vdc, 12 A Max. (When input: 200-277 V~)

Rated Power:144 W

12 Vdc, 8,4 A Max. (When input: 120-200 V~)

Rated Power: 100,8 W

Remark : Constant current + Constant voltage

Product data – type SLD-150-24

Output Rated : Max. 25 Vdc

24 Vdc, 6,3 A Max. (When input: 200-277 V~)

Rated Power: 151,2 W

24 Vdc, 4,41 A Max. (When input: 120-200 V~)

Rated Power: 105,84 W

Remark : Constant current + Constant voltage

Product data – type SLD-150-56

Output Rated : Max. 60 Vdc

24-56 Vdc, 2,68-4,17 A (When input: 200-277 V~)

Rated Power: 151,2 W

24-56 Vdc, 1,87-2,92 A Max. (When input: 120-200 V~)

Rated Power: 105 W

Remark : Constant current

TESTS

Test requirements

EN 61347-1:2015

EN 61347-1:2015/A1:2021 EN 61347-2-13:2014

EN 61347-2-13:2014/A1:2017

EN IEC 62384:2020



ANNEX TO ENEC CERTIFICATE 35-127559

page 2 of 3

Test result

The test results are laid down in DEKRA test file 439724400.

Additional information

The list of components is laid down in test report 4397244.50.

Conclusion

The examination proved that all requirements were met.

Factory location

MEAN WELL (GUANGZHOU) Electronics Co., Ltd. No.11 Jingu South Road, Huadu District, 510890 Guangzhou Guangdong, China



ANNEX TO ENEC CERTIFICATE 35-127559

page 3 of 3

Trade name : MEAN WELL stands for

