



# 中国国家强制性产品认证证书

证书编号: 2019011002181243

发证日期: 2022年09月06日

有效期至: 2024年05月05日

**认证委托人名称  
及注册地址** 明纬(广州)电子有限公司  
广州市花都区金谷南路11号

**产品生产者名称  
及注册地址** 明纬企业股份有限公司  
新北市五股区五权三路28号

**生产企业名称  
及生产地址** 明纬(广州)电子有限公司  
广州市花都区金谷南路11号

**产品名称和系列、  
规格、型号** LED模块用交流电子控制装置(LED控制装置,部分型号控制端口调光,独立式,恒流模式,安全特  
低电压,tc:90°C,I类,IP67,适宜直接安装在普通可燃材料表面,定温热保护:110°C)  
见附件。100-240V~50/60Hz

**产品标准和  
技术要求** GB 17625.1-2012;GB/T 17743-2021;GB 19510.1-2009;GB 19510.14-2009

上述产品符合 CNCA-C10-01:2014 认证规则的要求,特发此证。  
证书有效期内本证书的有效性依据发证机构的定期监督获得保持。  
本证书为变更证书,证书首次颁发日期:2019年05月05日  
经中国合格评定国家认可委员会认可 CNAS C001-P

可通过扫描下方二维码或登录国家认监委网站([www.cnca.gov.cn](http://www.cnca.gov.cn))查验证书信息



签发:

谢肇煦



中国质量认证中心







# CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

CERTIFICATE NO.: 2019011002181243

Valid from: Sep.06,2022

Valid until: May.05,2024

**NAME AND REGISTERED ADDRESS OF THE APPLICANT** MEAN WELL (Guangzhou) Electronics Co., Ltd.  
No.11 Jingu South Road, Huadu District, Guangzhou, China

**NAME AND REGISTERED ADDRESS OF THE MANUFACTURER** MEAN WELL Enterprises Co.,Ltd.  
No. 28, Wuquan 3rd Road, Wugu District, New Taipei City, Taiwan

**NAME AND LOCATION OF THE FACTORY** MEAN WELL (Guangzhou) Electronics Co., Ltd.  
No.11 Jingu South Road,Huadu District, Guangzhou, China

**PRODUCT MODEL(S)** A.C. Supplied Electronic Controlgear For LED Modules (Controlled Port Dimming for some type, Independent, Constant Current Mode, SELV, tc:90°C, Class I, IP67, Suitable For Direct Mounting On Normally Flammable Material, Temperature Declared Thermally Protected: 110°C) See Appendix. 100-240V ~ 50/60Hz

**STANDARDS AND TECHNICAL REQUIREMENTS** GB 17625.1-2012;GB/T 17743-2021;GB 19510.1-2009;GB 19510.14-2009

This is to certify that the above mentioned product(s) complies with the requirements of implementation rules for compulsory certification(REFNO. CNCA-C10-01:2014)

The validity of the certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

Date of original issued: May.05,2019

Accredited by China National Accreditation Service for Conformity Assessment CNAS C001-P

The certificate information is available through the QR code below or CNCA's website: [www.cnca.gov.cn](http://www.cnca.gov.cn)



SIGNATURE:

谢肇煦



CHINA QUALITY CERTIFICATION CENTRE







# 中国国家强制性产品认证证书

证书编号: 2019011002181243

第 1 页 共 1 页

本证书及附件应同时使用, 信息查验说明见证书页

纸号: 3077766

| 序号 | 产品型号         | 参数  | 备注            |
|----|--------------|---|---------------|
| 1. | XBG-160-A    | 输出: Max. 60Vd. c., 34-56Vd. c., 4. 1A, 159. 9W; | 不可调光<br>输入导线  |
| 2. | XBG-160-AB   | 输出: Max. 60Vd. c., 34-56Vd. c., 4. 1A, 159. 9W; | 可调光<br>输入导线   |
| 3. | XBG-160-A-C  | 输出: Max. 60Vd. c., 34-56Vd. c., 4. 1A, 159. 9W; | 不可调光<br>输入耦合器 |
| 4. | XBG-160-AB-C | 输出: Max. 60Vd. c., 34-56Vd. c., 4. 1A, 159. 9W; | 可调光<br>输入耦合器  |

输入: 100-240V~ 50/60Hz, ta:60℃(当输入电压为 200-240V~), ta:50℃(当输入电压为 100-200V~)

调光方式: 0-10Vdc电压信号输入调光、10VdcPWM信号调光、外接电阻调光



## 中国质量认证中心

