

CERTIFICATE

Issued to:
Applicant:
MEAN WELL Enterprises Co., Ltd.
No.28, Wuquan 3rd Rd, Wugu District
24891 New Taipei City, Taiwan

Licensee:
MEAN WELL Enterprises Co., Ltd.
No.28, Wuquan 3rd Rd, Wugu District
24891 New Taipei City, Taiwan

Product : Independent LED driver
Trade name(s) : MEAN WELL
Type(s)/model(s) : XLG-240-H-DA2, XLG-240-H-DA2-A, XLG-240I-H-DA2 and XLG-240I-H-DA2-A

The product and any acceptable variation thereto as specified in the Annex to this certificate and the documents therein referred to.

DEKRA hereby declares that the above-mentioned product has been certified on the basis of:

- a type test according to EN 61347-2-13:2014, EN 61347-2-13:2014/A1:2017, EN 61347-1:2015, EN 61347-1:2015/A1:2021 and EN IEC 62384:2020
- an inspection of the factory location according to CENELEC Operational Document CIG 021
- a DEKRA certification agreement with the number 2175773


DEKRA hereby grants the right to use the ENEC certification mark.

The ENEC certification mark may be applied to the product as specified in this certificate for the duration and under the conditions of the ENEC certification agreement.

This certificate is issued on 21 May 2023 and expires upon withdrawal of one of the above mentioned standards.

Certificate number: 35-128480 REV.1

DEKRA Certification B.V.



B.T.M. Holtus
Managing Director



K. Lin
Certification Manager

© Integral publication of this certificate is allowed

ACCREDITED BY THE
DUTCH ACCREDITATION
COUNCIL



SPECIFICATION OF THE CERTIFIED PRODUCT**Product data**

| | |
|----------------------------|---|
| Product | : Independent LED driver |
| Trade name(s) | : MEAN WELL |
| Type(s)/model(s) | : XLG-240-H-DA2, XLG-240-H-DA2-A, XLG-240I-H-DA2 and XLG-240I-H-DA2-A |
| Rated input current | : 2,7 A |
| Rated frequency | : 50/60 Hz |
| Max. case temperature (tc) | : 90 °C |
| Power factor | : 0,95 |
| Class of insulation | : Class I |
| Degree of protection | : IP67 |
| Additional information | : Thermal, short-circuit and overload protection, SELV, EL-mark, Constant current |

Product data – type XLG-240-H-DA2 and XLG-240I-H-DA2

| | |
|--------------------------|---|
| Ambient temperature (ta) | : 40 °C when input: 110-200 V~, 176-280 Vdc 50 °C when input: 200-240 V~ |
| Rated input voltage | : 110-240 V~, 176-280 Vdc |
| Output rated | : 65 Vdc max., 27-56 Vdc, 4,28-6,66 A, 239,6 W |

Product data – type XLG-240-H-DA2-A and XLG-240I-H-DA2-A

| | |
|--------------------------|---|
| Ambient temperature (ta) | : 35 °C when input: 110-200 V~, 176-280 Vdc 50 °C when input: 200-240 V~ |
| Rated input voltage | : 110-240 V~, 176-280 Vdc |
| Output rated | : 65 Vdc max., 27-56 Vdc, 4,28-6,66 A, 239,6 W |
| Additional information | : with auxiliary output (AUX: 12 Vdc, 0,25 A) |

TESTS**Test requirements**

EN 61347-2-13:2014
EN 61347-2-13:2014/A1:2017
EN 61347-1:2015
EN 61347-1:2015/A1:2021
EN IEC 62384:2020

Test result

The test results are laid down in DEKRA test file 439976000.

Additional information

This certificate replaces certificate No. 35-128480 which we hereby declare invalid.

The list of components is laid down in test report 4399760.50, 4399760.51.

Conclusion

The examination proved that all requirements were met.

Factory locations

YONGDEN TECHNOLOGY CORPORATION
345 MacArthur HighWay Tabang,
3015 Guiguinto, Bulacan, The Philippines

MEAN WELL (GUANGZHOU) Electronics Co., Ltd.
No.11 Jingu South Road, Huadu District,
510890 Guangzhou Guangdong, China

Trade name(s) : MEAN WELL stands for

