

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

### **CB TEST CERTIFICATE**

Product

Name and address of the applicant

Name and address of the manufacturer

Name and address of the factory

Ratings and principal characteristics

Trademark (if any)

Customer's Testing Facility (CTF) Stage used Model / Type Ref.

Additional information (if necessary may also be reported on page 2)

A sample of the product was tested and found to be in conformity with

As shown in the Test Report Ref. No. which forms part of this Certificate

Independent LED Driver

MEAN WELL Enterprises Co., Ltd. No. 28, Wuquan 3rd Rd. Wugu District New Taipei City 24891, Taiwan

MEAN WELL Enterprises Co., Ltd. No. 28, Wuquan 3rd Rd. Wugu District New Taipei City 24891, Taiwan

See additional page(s)

AC Input : 1)100-240V, 1.0A, 50/60Hz; 277V, 0.38A, 50/60Hz (277V only for North America); 2)3)100-240V, 1.0A,  $50/60 \mathrm{Hz}$ 

Class I

DC Output: 1)12V, 5.0A, 60.0W; 24V, 3.1A, 74.4W; 53-107V, 0.7-1.05A, 74.9W; 27-56V, 1.3-2.1A, 75.6W; 2)12V, 5.0A, 60.0W; 3)24V, 3.1A, 74.4W

MEAN WELL (Logo)

1) XLG-75x-y-z, 2) XLG-75-12-CV, 3) XLG-75-24-CV (x=blank or I, y=12, 24, L or H, z=blank, A or AB, AB for 24, H, L only)


For model differences, refer to the test report. Re-issue of DE 2-036455-M1 dated 14.07.2023, due to second modification.

IEC 61347-2-13:2014+A1 IEC 61347-1:2015+A1

See Test Report for National Differences

CN22TAVY

This CB Test Certificate is issued by the National Certification Body



2024-09-13

TÜV Rheinland LGA Products GmbH Tillystr. 2, 90431 Nürnberg, Germany

Phone + 49 221 806-1371 Fax + 49 221 806-3935

Mail: cert-validity@de.tuv.com Web: www.tuv.com

Signature:

Spark Li

0/061 CB 06/20v9 rl

Date:

Disclaimer: This is an electronically released document. The authenticity of this certificate can be verified on the IECEE Website "http://certificates.iecee.org"



Page 2 of 2

- MEAN WELL Enterprises
   Co.,Ltd.
   No. 28, Wuquan 3rd Rd. Wugu District
   New Taipei City 24891
   Taiwan
- 2. Suzhou MEAN WELL Technology Co., Ltd. No. 77, Jian-Min Road, Dong-Qiao, Pan-Yang Ind. Park, Huang-Dai Town, Xiang-Cheng District, Suzhou, 215152 Jiangsu, P.R. China
- MEAN WELL (GUANGZHOU) Electronics
   Co., Ltd.
   No. 11 Jingu South Road, Huadu District,
   Guangzhou
   510890 Guangdong, P.R. China
- 4. Yongden Technology Corporation 345 MacArthur Highway, Tabang, Guiguinto, Bulacan 3015 Philippines
- 5. MEAN WELL INDIA ELECTRONICS PRIVATE LIMITED 9C, Peenya industrial area, Chokkasandra, 2ND PHASE, PEENYA, Bengaluru (Bangalore) Urban, Karnataka, 560058 India

Additional information (if necessary) Report Ref. No. : CN22TAVY 003

 $\int$ 

Date: 2024-09-13 Signature: Spark Li



### IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

# **CB TEST CERTIFICATE**

Product

Name and address of the applicant

Name and address of the manufacturer

Name and address of the factory

Ratings and principal characteristics

Trademark (if any)

Customer's Testing Facility (CTF) Stage used Model / Type Ref.

Additional information (if necessary may also be reported on page 2)

A sample of the product was tested and found to be in conformity with

As shown in the Test Report Ref. No. which forms part of this Certificate

Independent LED Driver

MEAN WELL Enterprises Co., Ltd. No. 28, Wuquan 3rd Rd. Wugu District New Taipei City 24891 Taiwan

MEAN WELL Enterprises Co., Ltd. No. 28, Wuquan 3rd Rd. Wugu District New Taipei City 24891 Taiwan

See additional page(s)

AC Input: 100-240V, 50/60Hz, 1.0A, 277V, 50/60Hz, 0.38A(277V only for North America); Class I DC Output: 12V, 5.0A, 60.0W; 24V, 3.1A, 74.4W; 53-107V, 0.7-1.05A, 74.9W; 27-56V, 1.3-2.1A, 75.6W.

MEAN WELL (Logo)

24, H, L only)

N/A

XLG-75x-y-z (x=blank or I; y=12, 24, L or H; z=blank, A or AB, AB for

For model differences, refer to the test report. Re-issue of DE 02-36455 dated 06.09.2022,

due to first modification.

IEC 61347-2-13:2014+A1 IEC 61347-1:2015+A1

See Test Report for National Differences

CN22TAVY

This CB Test Certificate is issued by the National Certification Body



TÜV Rheinland LGA Products GmbH Tillystr. 2, 90431 Nürnberg, Germany Phone + 49 221 806-1371 Fax + 49 221 806-3935

Spark Li

Mail: cert-validity@de.tuv.com Web: www.tuv.com

2023-07-14 Signature:

Date:



Page 2 of 2

- MEAN WELL Enterprises
   Co., Ltd.
   No. 28, Wuquan 3rd Rd. Wugu District
   New Taipei City 24891
   Taiwan
- 2. Suzhou MEAN WELL Technology Co., Ltd. No. 77, Jian-Min Road, Dong-Qiao, Pan-Yang Ind. Park, Huang-Dai Town, Xiang-Cheng District, Suzhou, 215152 Jiangsu, P.R. China
- MEAN WELL (GUANGZHOU) Electronics Co., Ltd.
  No. 11 Jingu South Road, Huadu District, Guangzhou
  510890 Guangdong, P.R. China
- 4. Yongden Technology Corporation 345 MacArthur Highway, Tabang, Guiguinto, Bulacan 3015 Philippines
- 5. MEAN WELL INDIA ELECTRONICS PRIVATE LIMITED 9C, Peenya industrial area, Chokkasandra, 2ND PHASE, PEENYA, Bengaluru (Bangalore) Urban, Karnataka, 560058 India

Additional information (if necessary)

Report Ref. No.: CN22TAVY 002

5

Date: 2023-07-14 Signature: Spark Li



DE 2-036455

## IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

### **CB TEST CERTIFICATE**

Product

Name and address of the applicant

Name and address of the manufacturer

Name and address of the factory

Ratings and principal characteristics

Trademark (if any)

Customer's Testing Facility (CTF) Stage used Model / Type Ref.

Additional information (if necessary may also be reported on page 2)

A sample of the product was tested and found to be in conformity with

As shown in the Test Report Ref. No. which forms part of this Certificate

LED Driver

MEAN WELL Enterprises Co., Ltd. No. 28, Wuquan 3rd Rd. Wugu District New Taipei City 24891 Taiwan

MEAN WELL Enterprises Co., Ltd. No. 28, Wuquan 3rd Rd. Wugu District New Taipei City 24891 Taiwan

See additional page(s)

AC Input: 100-240V, 50/60Hz, 1.0A, 277V, 50/60Hz, 0.38A(277V only for North America); Class I DC Output: 12V, 5.0A, 60.0W; 24V, 3.1A, 74.4W; 53-107V, 0.7-1.05A, 74.9W; 27-56V, 1.3-2.1A, 75.6W

MEAN WELL (Logo)

N/A

XLG-75x-y-z (x=blank or I; y=12, 24, L or H; z=blank, A or AB, AB for 24, H, L only)

For model differences, refer to the test report.

IEC 61347-2-13:2014+A1 IEC 61347-1:2015+A1 See Test Report for National Differences

CN22TAVY

This CB Test Certificate is issued by the National Certification Body



2022-09-06

TÜV Rheinland LGA Products GmbH Tillystr. 2, 90431 Nürnberg, Germany Phone + 49 221 806-1371 Fax + 49 221 806-3935

Mail: cert-validity@de.tuv.com

001

Web : www.tuv.com

Signature: Spark Li

Date:



DE 2-036455

Page 2 of 2

- Suzhou MEAN WELL Technology Co., Ltd. No. 77, Jian-Min Road, Dong-Qiao, Pan-Yang Ind. Park, Huang-Dai Town, Xiang-Cheng District, Suzhou, 215152 Jiangsu, P.R. China
- 2. Yongden Technology Corporation 345 MacArthur Highway, Tabang, Guiguinto, Bulacan 3015 Philippines
- MEAN WELL (GUANGZHOU) Electronics
   Co., Ltd.
   No. 11 Jingu South Road, Huadu District,
   Guangzhou
   510890 Guangdong, P.R. China
- 4. MEAN WELL Enterprises Co.,Ltd. No. 28, Wuquan 3rd Rd. Wugu District New Taipei City 24891 Taiwan
- 5. MEAN WELL INDIA ELECTRONICS PRIVATE LIMITED 9C, Peenya industrial area, Chokkasandra, 2ND PHASE, PEENYA, Bengaluru (Bangalore) Urban, Karnataka, 560058 India

Additional information (if necessary)

Report Ref. No.: CN22TAVY 001

5~

Spark Li

**Date:** 2022-09-06 **Signature:**